

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO: 3240-0554:137

Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: Johnson Controls, 507 E. Michigan Street, Milwaukee, WI 53202-5211
Contact: *James D. Kinney (414) 524-4358

DESIGN: Model FDH300P duct smoke detector. Unit consists of an enclosure, electrical components, sampling and exhaust tubes and listed photoelectric smoke detector sensor. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, air velocity rating and UL label.

APPROVAL: Listed as a duct smoke detector for use in HVAC systems having air velocities between 500 to 4000 ft/min. Suitable for use with separately listed compatible fire alarm control units.

XLF: 3240-0028:205

*Rev. 06-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 11, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager